

NATIONAL ASSOCIATION FOR STATE COMMUNITY SERVICES PROGRAMS



# Equity and Electrification

(aka Beneficial Electrification in Weatherization)

20  
23

ANNUAL TRAINING  
**CONFERENCE**

SEPTEMBER 25 - 29



G R A N D R A P I D S

# Equity and Electrification

(aka Beneficial Electrification in Weatherization)

Paul Francisco

Director, Indoor Climate Research & Training



CHAMPAIGN COUNTY  
REGIONAL PLANNING  
COMMISSION



# Electrification is all the rage

- Reduces emissions\* to help address climate change and improve health
- Interfaces with renewable energy
- Reduces reliance on foreign fuels
- Improves resiliency since there are multiple ways to generate electricity
- Reduces costs (?)

\*Assumes that the source of electricity generation has lower emissions

# Electrification and Heat Pumps

- Central to electrification programs and climate plans
- Done right, can often be a good thing for many people
- Done wrong, can hurt people



Source: U.S. DOE

# Water Heating

- From Rewiring America:
  - “Critically, we classify a household as "in the money" if it has at least one electrification project that saves money compared to current bills. In many cases, this electrification project is water heating.” (emphasis added)

(<https://www.rewiringamerica.org/about/methodology>)


# Reduce costs?

- Let's look at this
- Assumptions:
  - Any new appliance will need to meet Energy Star®
    - NG furnaces 95%/90% (north/south)
    - Heat pumps HSPF2 8.1/7.8 (cold climate/other)

# Initial assumptions (to be revisited)

- No duct losses
- Heat pump installed to get maximum beneficial compressor output
- Heat pump HSPF2 is correct for location\*
  - HSPF2 came into effect in 2023
  - It more accurately reflects actual performance
  - Efficiencies are lower than HSPF, e.g. Energy Star for HSPF was 8.2, for HSPF2 it will be 7.8


\*Assumes climate zone 4



Source: AHRI Standard 210/240-2023



# Climate Zone Assumption Impact



Note: uses old HSPF procedure...  
newer HSPF2 procedure brings it  
more in line with actual  
performance

# Framing

- Can look at fuel cost ratios
- Can look at necessary HSPF2
- Use marginal fuel prices (i.e. per therm/kWh charges)
- If heat pump is more expensive, what else needs to be done to offset?

# Equations

- $\frac{\$/therm}{\$/kWh} = \frac{29.3 * \eta_{gas}}{sCOP}$  (sets cost ratio; sCOP = HSPF2/3.413)
- $HSPF2 = 3.413 * sCOP = 3.413 * \frac{29.3 * \eta_{gas} * \$/kWh}{\$/therm}$


(minimum HSPF2 to make heat pump lower cost)

# Outcomes (cost ratio)

- For cold climates (95% NG furnace vs. ccHP HSPF2 = 8.1)
  - If \$/therm < 11.7\*\$ /kWh, NG furnace is cheaper
  - *(Ratio is about 9.9 if you compare to an 80% furnace)*
- For other (90% NG furnace vs. ccHP HSPF2 = 7.8)
  - If \$/therm < 11.5\*\$ /kWh, NG furnace is cheaper

# Evaluate 11 locations, January 2022 rates

| Location        | Natural Gas Cost,<br>\$/therm | Electricity Cost,<br>\$/kWh |
|-----------------|-------------------------------|-----------------------------|
| Northern Sites  |                               |                             |
| Denver, CO      | \$0.81                        | \$0.117                     |
| Chicago, IL     | \$0.84                        | \$0.096                     |
| Baltimore, MD   | \$0.69                        | \$0.083                     |
| Minneapolis, MN | \$0.83                        | \$0.060                     |
| New York        | \$1.14                        | \$0.183                     |
| Burlington, VT  | \$1.21                        | \$0.177                     |
| Seattle, WA     | \$1.00                        | \$0.105                     |
| Charleston, WV  | \$0.99                        | \$0.079                     |
| Southern Sites  |                               |                             |
| Tampa, FL       | \$1.40                        | \$0.136                     |
| Atlanta, GA     | \$0.76                        | \$0.099                     |
| Albuquerque, NM | \$0.35                        | \$0.101                     |



# Outcomes (needed HSPF2)

| Location        | Natural Gas Cost,<br>\$/therm | Electricity Cost,<br>\$/kWh | Minimum<br>HSPF2 |
|-----------------|-------------------------------|-----------------------------|------------------|
| Northern Sites  |                               |                             |                  |
| Denver, CO      | \$0.81                        | \$0.117                     | 13.7             |
| Chicago, IL     | \$0.84                        | \$0.096                     | 10.9             |
| Baltimore, MD   | \$0.69                        | \$0.083                     | 11.4             |
| Minneapolis, MN | \$0.83                        | \$0.060                     | 6.9              |
| New York        | \$1.14                        | \$0.183                     | 15.3             |
| Burlington, VT  | \$1.21                        | \$0.177                     | 13.9             |
| Seattle, WA     | \$1.00                        | \$0.105                     | 10.0             |
| Charleston, WV  | \$0.99                        | \$0.079                     | 7.6              |
| Southern Sites  |                               |                             |                  |
| Tampa, FL       | \$1.40                        | \$0.136                     | 8.7              |
| Atlanta, GA     | \$0.76                        | \$0.099                     | 11.7             |
| Albuquerque, NM | \$0.35                        | \$0.101                     | 26.0             |

# Now about those ducts...





# From Ecotope report...


|               | n          | Leakage (% of airflow) |             |
|---------------|------------|------------------------|-------------|
|               |            | Supply                 | Return      |
| <b>Bend</b>   | 28         | 14.5                   | 10.9        |
| <b>Clark</b>  | 34         | 9.7                    | 11.3        |
| <b>Kitsap</b> | 40         | 14.1                   | 14.9        |
| <b>Yakima</b> | 33         | 12.6                   | 13.1        |
| <b>Total</b>  | <b>135</b> | <b>12.8</b>            | <b>12.7</b> |

Baylon et. al. 2005. Analysis of Heat Pump Installation Practices and Performance


# Example

- Assume a house with 10% leakage to outside on either supply or return
- Assume the supply ducts are insulated to an effective R-4
- Assume the return ducts are uninsulated (panned?)


# Impact of Ducts - Seattle



# Impact of Ducts - Spokane



# Weather Profiles



Fraction of Heating Season Hours

# Implications

- Assume 1500 square foot house
- Assume crawl space with ducts
- Assume 2-ton HP is sized to meet the load (balance point) at 30 °F
- Assume alternative is a furnace

# Duct Efficiency Results – Supply Losses

|                           | N. Bend                    | Portland | Medford | Boise | Spokane | Missoula |
|---------------------------|----------------------------|----------|---------|-------|---------|----------|
| Loss Component            | Annual Duct Efficiency (%) |          |         |       |         |          |
| <b>Supply – furnace</b>   |                            |          |         |       |         |          |
| 20% leak                  | 77.2                       | 78.2     | 75.9    | 76.3  | 76.3    | 75.8     |
| 10% leak                  | 88.7                       | 88.3     | 88.0    | 88.2  | 88.2    | 88.0     |
| R-1.5 ducts               | 86.7                       | 86.3     | 85.9    | 86.3  | 86.2    | 85.8     |
| R-4 ducts                 | 94.8                       | 94.6     | 94.4    | 94.5  | 94.5    | 94.4     |
| R-8 ducts                 | 97.3                       | 97.2     | 97.2    | 97.2  | 97.2    | 97.1     |
| <b>Supply – heat pump</b> |                            |          |         |       |         |          |
| 20% leak                  | 72.0                       | 67.9     | 64.1    | 59.6  | 58.9    | 57.7     |
| 10% leak                  | 86.4                       | 84.5     | 82.5    | 78.7  | 78.3    | 77.0     |
| R-1.5 ducts               | 83.6                       | 81.5     | 79.4    | 75.0  | 74.6    | 73.1     |
| R-4 ducts                 | 93.3                       | 92.2     | 91.4    | 89.6  | 88.9    | 87.9     |
| R-8 ducts                 | 96.6                       | 96.0     | 95.9    | 94.6  | 94.6    | 94.0     |

# Duct Efficiency Results – Return Losses

|                           | N. Bend                    | Portland | Medford | Boise | Spokane | Missoula |
|---------------------------|----------------------------|----------|---------|-------|---------|----------|
| Loss Component            | Annual Duct Efficiency (%) |          |         |       |         |          |
| <b>Return – furnace</b>   |                            |          |         |       |         |          |
| 20% leak                  | 96.9                       | 96.6     | 96.3    | 96.6  | 96.4    | 96.0     |
| 10% leak                  | 98.5                       | 98.3     | 98.2    | 98.3  | 98.2    | 98.0     |
| R-1.5 ducts               | 98.8                       | 98.6     | 98.5    | 98.6  | 98.6    | 98.5     |
| R-4 ducts                 | 99.5                       | 99.5     | 99.4    | 99.5  | 99.5    | 99.4     |
| R-8 ducts                 | 99.8                       | 99.7     | 99.7    | 99.7  | 99.7    | 99.7     |
| <b>Return – heat pump</b> |                            |          |         |       |         |          |
| 20% leak                  | 92.9                       | 90.8     | 89.1    | 85.4  | 84.4    | 82.7     |
| 10% leak                  | 96.6                       | 95.5     | 94.9    | 93.1  | 92.5    | 91.4     |
| R-1.5 ducts               | 97.4                       | 96.5     | 96.1    | 94.5  | 94.4    | 93.6     |
| R-4 ducts                 | 99.0                       | 98.7     | 98.5    | 97.8  | 97.8    | 97.5     |
| R-8 ducts                 | 99.5                       | 99.4     | 99.3    | 98.9  | 98.9    | 98.7     |



# Duct Efficiency Results – Relative Losses

|                | N. Bend                               | Portland | Medford | Boise | Spokane | Missoula |
|----------------|---------------------------------------|----------|---------|-------|---------|----------|
| Loss Component | % Worse Duct Efficiency for Heat Pump |          |         |       |         |          |
| <b>Supply</b>  |                                       |          |         |       |         |          |
| 20% leak       | 123%                                  | 147%     | 149%    | 170%  | 173%    | 175%     |
| 10% leak       | 120%                                  | 132%     | 146%    | 181%  | 184%    | 192%     |
| R-1.5 ducts    | 123%                                  | 135%     | 146%    | 182%  | 184%    | 189%     |
| R-4 ducts      | 129%                                  | 144%     | 154%    | 189%  | 202%    | 216%     |
| R-8 ducts      | 126%                                  | 143%     | 146%    | 193%  | 193%    | 207%     |
| <b>Return</b>  |                                       |          |         |       |         |          |
| 20% leak       | 229%                                  | 271%     | 295%    | 429%  | 433%    | 432%     |
| 10% leak       | 227%                                  | 265%     | 283%    | 406%  | 417%    | 430%     |
| R-1.5 ducts    | 217%                                  | 250%     | 260%    | 393%  | 400%    | 427%     |
| R-4 ducts      | 200%                                  | 260%     | 250%    | 440%  | 440%    | 417%     |
| R-8 ducts      | 250%                                  | 200%     | 233%    | 367%  | 367%    | 433%     |


# Controls

- How is the heat pump designed to operate?
- Maximize effective compressor use?
- Outdoor thermostat? – prevents backup above a certain temperature
- Low-ambient lockout? – prevents compressor use below a certain temperature even if it could be useful
- Backup comes on at stage 1?



# All following results from Ecotope projects...


## Outdoor Thermostats Typically Installed?



n=32

Baylon et. al. 2005. Analysis of Heat Pump Installation Practices and Performance

# All following results from Ecotope projects...




n=32

Baylon et. al. 2005. Analysis of Heat Pump Installation Practices and Performance

# All following results from Ecotope projects...

## Element wired in first stage heating?




n=32

Baylon et. al. 2005. Analysis of Heat Pump Installation Practices and Performance

# And then there's this...

Needs a wire to tell the reversing valve to activate



# Takeaways on controls

- Goal (and assumption) is to get the most out of the compressor possible
  - Outdoor thermostat enabled
  - No low-ambient cutoff
  - Backup NOT wired to come on in stage 1
  - Make sure the reversing valve is actually wired to activate
- However, there are a substantial number of cases where installations prioritize avoiding comfort complaints over efficiency
  - ...or make other mistakes

# So... what do we do?

- Quality assurance
- Quality control
- Quality assurance
- Quality control
- Repeat as necessary



# So... what ELSE do we do?

- Recognize that many families will see costs go up with heat pumps if nothing else is done
- What policies can be put in place to offset the increase?
- Site solar?
- Is additional energy efficiency a possible solution?

# Summary

- Over time, heat pumps will likely be better than fuel-fired heating systems from both climate and cost perspectives
- Right now, they often are not
- Duct losses and control problems (both unintentional and intentional) can further impact heat pumps in a greater way than they impact furnaces – especially vital to evaluate in retrofit situations
- QA/QC should not be optional – it should be a mandatory component of any electrification program that includes heating systems

## EVALUATION QR CODE

